

Clearitas Municipal Dosing Table

The following table presents the volume of Clearitas needed to treat daily water volumes from 100,000 gpd to 500,000 gpd using dosages from 5 ppm to 20 ppm. Note that most municipal applications will use a dosage of 10 ppm, however, dosages may need to be adjusted up or down based on the actual condition of the system.

| Water Treated | Vol. of Clearitas (5 ppm Dosage) | Vol. of Clearitas (10 ppm Dosage) | Vol. of Clearitas (15 ppm Dosage) | Vol. of Clearitas (20 ppm Dosage) |
|---------------|-------------------------------------|---|---|---|
| 100,000 gpd | 0.50 gpd | 1.00 gpd | 1.50 gpd | 2.00 gpd |
| 150,000 gpd | 0.75 gpd | 1.50 gpd | 2.25 gpd | 3.00 gpd |
| 200,000 gpd | 1.00 gpd | 2.00 gpd | 3.00 gpd | 4.00 gpd |
| 250,000 gpd | 1.25 gpd | 2.50 gpd | 3.75 gpd | 5.00 gpd |
| 300,000 gpd | 1.50 gpd | 3.00 gpd | 4.50 gpd | 6.00 gpd |
| 350,000 gpd | 1.75 gpd | 3.50 gpd | 5.25 gpd | 7.00 gpd |
| 400,000 gpd | 2.00 gpd | 4.00 gpd | 6.00 gpd | 8.00 gpd |
| 450,000 gpd | 2.25 gpd | 4.50 gpd | 6.75 gpd | 9.00 gpd |
| 500,000 gpd | 2.50 gpd | 5.00 gpd | 7.50 gpd | 10.00 gpd |